





of OII & Gas.

Procus

IOGP S-754 Transformers (IEEE)

Questions for Manufacturers – JIP33 Public Review February 2025

Tom Wren - Project Engineer



Anti-trust/anti-competition

- IOGP Competition Law Guidelines available on the <u>JIP33 website</u>.
- Do not share any cost or pricing details in the public review contact PE directly.



About Us

The JIP33 Work Groups perform their activities in accordance with IOGP Competition Law Guidelines



IOGP S-754 – Specific Questions for Manufacturers (instructions)

- In addition to your other comments on the specification in Jama, please provide responses to the questions on the following slides.
 - Please use Jama to provide this feedback by adding a comment in the referenced clause numbers.
 - Please comment on all 4 specification documents, don't just provide answers to these questions only.
- Remember no proprietary or commercial comments, the Jama review is public!
- Thank you in advance for your input.



IOGP S-754 – Specific Questions for Manufacturers (1/4)

- S-754 Normative Reference "ABS MODU, Publication Number 6 Part 4":
 - Has ABS MODU been replaced with MOU Rules Rules for Building and Classing Mobile Offshore Units?
 - Do you use this document to certify to?
- S-754 Clause 5.13.4 and 5.13.4 NOTE:
 - "If the transformer is specified for offshore floating or marine applications, the transformer shall be provided in accordance with USCG 46 CFR 111.20 and ABS MODU Rules 4-3-4/9."
 - "NOTE—Additional guidance and information for transformers installed on floating facilities in US territorial waters to USCG and ABS codes can be found in in API 14F or API 14FZ."
 - For transformers installed in floating offshore or marine applications is this the correct reference for the requirements for these applications USCG 46 CFR 111.20 and ABS MODU Rules 4-3-4/9?
 - If not, what is the reference you use?

4

• Do you normally or have you ever considered the requirements in API Recommended Practice 14F or API Recommended Practice 14FZ for transformers installed offshore?



IOGP S-754 – Specific Questions for Manufacturers (2/4)

- S-754 Clause 6.3.1.3:
 - "Wiring for CTs shall be No. 12 AWG stranded copper or larger."
 - In the JIP33 S-743 MC Switchgear specification we changed to 12 AWG based on manufacturer feedback, and have done the same here with ANSI transformers.
 - What is your standard CT wiring size for transformers?
- S-754 Clause 6.5.3.8:
 - "Tanks, compartments and radiators shall be suitable for vacuum filling at an external pressure of 101.325 kPa (one atmosphere), i.e., full vacuum."
 - What is the pressure requirement for vacuum filling in the field? (Is 1 atmosphere the right requirement?)
- S-754 Clause 6.14.3.4 and 6.14.3.5:
 - "If provisions for future forced air-cooling fans are specified, the control cabinet shall be provided with the relays, motor starters, HOA controls, and interconnect wiring for fan operation."
 - "If provisions for future forced air-cooling fans are specified, the control cabinet shall be provided with terminal blocks to facilitate field wiring and power supply interconnection."
 - What do you normally provide when requested to provide provisions for fans?



IOGP S-754 – Specific Questions for Manufacturers (3/4)

- S-754 Clause 6.15.1.6:
 - "If a non-vacuum OLTC is specified, the OLTC oil vessel shall be provided with a protective device monitoring sudden-flow conditions."
 - When providing a non-vacuum OLTC on a power transformer, do you normally provide a separate sudden flow/pressure relay?
- S-754 Clause 6.16.6:
 - "If the transformer is specified for offshore or marine applications, the transformer shall be designed in accordance with API RP 2A-WSD and API RP 2A-LRFD."
 - "NOTE—Additional motions criteria (e.g., static/dynamic tilt, period, lateral/vertical acceleration) can be provided in the supplemental tab or project documents."
 - If the transformer is specified for offshore or marine applications, do you use the design requirements from API RP 2A-WSD and API RP 2A-LRFD for handling, lifting, or operating stresses? If not, what do you use?
- S-754 Clause 10.1.1:
 - "Transformers less than 40 MVA shall be shipped filled with insulating liquid, except for conservator-type."
 - For a sealed tank unit, when do you ship the unit dry?
 - Is 40 MVA a good number for this cut-off value?



IOGP S-754 – Specific Questions for Manufacturers (4/4)

- S-754 Clause 10.1.2:
 - "Transformers less than 40 MVA shall be shipped with the radiators attached to the transformer tank, except conservator-type."
 - For a sealed tank unit, when do you ship the unit with the radiators shipped loose?
 - Is 40 MVA a good number for this cut off value?
- S-754 Clause 12.1.8:
 - "Indicating devices provided for determining the status of the pad-mounted transformer shall be viewable without exposing personnel to energized components."
 - For your standard pad-mounted transformer, is this a major change or minor change?
- S-754 Data sheet option "Pad-mounted sampling location"
 - Ability to select 2 options: "manufacturer standard" or "external from terminations"
 - For pad mounted transformers is this a major or minor change?
- Is the transformer oil specified always applicable to the OLTC? (e.g., if natural ester is specified, does the OLTC also come with natural ester?)









of OIL& Gas

PLOCIE:+D



т.	±1	712	

T: +1 713 261 0411 E: reception-americas@iogp.org **IOGP Asia Pacific** T: +60 3-3099 2286 E: reception-asiapacific@iogp.org **IOGP** Europe T: +32 (0)2 790 7762 E: reception-europe@iogp.org **IOGP Middle East & Africa**

T: +1 713 261 0411 E: reception-mea@iogp.org www.iogp-jip33.org