

Quality Requirements for Liquid-Immersed Distribution, Power and Regulating Transformers (IEEE)

Public Review Draft



Revision history

VERSION	DATE	PURPOSE
0.1	January 2025	Issued for Public Review

Acknowledgements

This IOGP Specification was prepared by a Joint Industry Programme 33 Standardization of Equipment Specifications for Procurement organized by IOGP with support by the World Economic Forum (WEF).

Disclaimer

Whilst every effort has been made to ensure the accuracy of the information contained in this publication, neither IOGP nor any of its Members past present or future warrants its accuracy or will, regardless of its or their negligence, assume liability for any foreseeable or unforeseeable use made thereof, which liability is hereby excluded. Consequently, such use is at the recipient's own risk on the basis that any use by the recipient constitutes agreement to the terms of this disclaimer. The recipient is obliged to inform any subsequent recipient of such terms.

Please note that this publication is provided for informational purposes and adoption of any of its recommendations is at the discretion of the user. Except as explicitly stated otherwise, this publication must not be considered as a substitute for government policies or decisions or reference to the relevant legislation relating to information contained in it.

Where the publication contains a statement that it is to be used as an industry standard, IOGP and its Members past, present, and future expressly disclaim all liability in respect of all claims, losses or damages arising from the use or application of the information contained in this publication in any industrial application.

Any reference to third party names is for appropriate acknowledgement of their ownership and does not constitute a sponsorship or endorsement.

Copyright notice

The contents of these pages are © International Association of Oil & Gas Producers. Permission is given to reproduce this report in whole or in part provided (i) that the copyright of IOGP and (ii) the sources are acknowledged. All other rights are reserved. Any other use requires the prior written permission of IOGP.

These Terms and Conditions shall be governed by and construed in accordance with the laws of England and Wales. Disputes arising here from shall be exclusively subject to the jurisdiction of the courts of England and Wales.

Foreword

This specification was prepared under Joint Industry Programme 33 (JIP33) "Standardization of Equipment Specifications for Procurement" organized by the International Oil & Gas Producers Association (IOGP) with the support from the World Economic Forum (WEF). Companies from the IOGP membership participated in developing this specification to leverage and improve industry level standardization globally in the oil and gas sector. The work has developed a minimized set of supplementary requirements for procurement, with life cycle cost in mind, resulting in a common and jointly agreed specification, building on recognized industry and international standards.

Recent trends in oil and gas projects have demonstrated substantial budget and schedule overruns. The Oil and Gas Community within the World Economic Forum (WEF) has implemented a Capital Project Complexity (CPC) initiative which seeks to drive a structural reduction in upstream project costs with a focus on industry-wide, non-competitive collaboration and standardization. The CPC vision is to standardize specifications for global procurement for equipment and packages. JIP33 provides the oil and gas sector with the opportunity to move from internally to externally focused standardization initiatives and provide step change benefits in the sector's capital projects performance.

This specification has been developed in consultation with a broad user and supplier base to realize benefits from standardization and achieve significant project and schedule cost reductions.

The JIP33 work groups performed their activities in accordance with IOGP's Competition Law Guidelines (November 2020).

Table of contents

Foreword.....	1
Introduction	3
1 Scope	4
2 Normative references	4
3 Terms, definitions and abbreviated terms	4
3.1 Terms and definitions	4
3.2 Abbreviated terms	5
4 Quality requirements	5
4.1 Quality management system (QMS).....	5
4.2 Conformity assessment system (CAS)	6
5 Certification and traceability	6
6 Evidence — conformance records	6
Annex A (normative) Purchaser conformity assessment requirements	7

List of tables

Table A.1 — Purchaser conformity assessment requirements.....	7
---	---

Introduction

The purpose of this quality requirements specification (QRS) is to specify quality management requirements and the proposed extent of purchaser intervention activities for the procurement of liquid-immersed distribution, power and regulating transformers in accordance with IOGP S-754 for application in the petroleum and natural gas industries.

Purchaser intervention activities are identified through the selection of one of four conformity assessment system (CAS) levels based on a risk and criticality assessment. The applicable CAS level is specified by the purchaser in the procurement data sheet (PDS) or purchase order.

The IOGP S-754 specification documents follow a common structure (as shown below) comprising a specification, also known as a technical requirements specification (TRS), a PDS, an information requirements specification (IRS) and this QRS. These four specification documents, together with the purchase order, define the overall technical specification for procurement.



JIP33 Specification for Procurement Documents Quality Requirements Specification (QRS)

This QRS is to be applied in conjunction with the specification, the PDS and the IRS, referred to in this document as IOGP S-754, IOGP S-754D and IOGP S-754L respectively. Further information on the purpose of these documents and the order of precedence for their use is provided in the introduction of the specification.

1 Scope

This QRS specifies quality management requirements for the supply of liquid-immersed distribution, power and regulating transformers to IOGP S-754 including:

- a) manufacturer quality management system (QMS) requirements;
- b) purchaser conformity assessment (surveillance and inspection) activities;
- c) traceability requirements.

2 Normative references

For the purpose of this document, the documents referenced in IOGP S-754 and those listed below, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

API Specification Q1, *Specification for Quality Management System Requirements for Manufacturing Organizations for the Petroleum and Natural Gas Industry*

IOGP S-754, *Supplementary Specification to IEEE Std C57.12.00 for Liquid-Immersed Distribution, Power and Regulating Transformers*

ISO 9000:2015, *Quality management systems — Fundamentals and vocabulary*

ISO 9001:2015, *Quality management systems — Requirements*

ISO 29001, *Petroleum, petrochemical and natural gas industries — Sector-specific quality management systems — Requirements for product and service supply organizations*

ISO 10005, *Quality management — Guidelines for quality plans*

3 Terms, definitions and abbreviated terms

3.1 Terms and definitions

For the purpose of this document, the terms and definitions given in IOGP S-754 and ISO 9000:2015 (normative to ISO 9001:2015) and the following shall apply.

3.1.1

conformity assessment

demonstration that specified requirements are fulfilled

Note 1 to entry: "Conformity assessment" is also referred to as "assessment".

Note 2 to entry: Conformity assessment includes review, inspection, verification and validation activities.

Note 3 to entry: Conformity assessment activities may be undertaken at manufacturer/sub-supplier premises, virtually by video link, desktop sharing, etc. or by review of information.

3.1.2

conformity assessment system

CAS

system that provides different levels of purchaser interventions to assess and verify supplier conformance to specified requirements

Note 1 to entry: CAS level A applies to the highest risk and associated extent of verification. CAS level D is the lowest.

3.1.3

hold point

H

<conformity assessment> point in the chain of activities beyond which an activity shall not proceed without the approval of the purchaser or purchaser's representative

3.1.4

witness point

W

<conformity assessment> point in the chain of activities at which the manufacturer shall notify the purchaser or purchaser's representative before proceeding

Note 1 to entry: The operation or process may proceed without witness if the purchaser does not attend after the agreed notice period.

3.1.5

surveillance

S

<conformity assessment> observation, monitoring or review, by the purchaser or purchaser's representative, of an activity, operation, process, product or associated information

3.1.6

review

R

<conformity assessment> review of the manufacturer's records, procedures and supporting information to verify and/or validate conformance to requirements

3.2 Abbreviated terms

CAS	conformity assessment system
FAT	factory acceptance test
IRS	information requirements specification
ITP	inspection and test plan
PDS	procurement data sheet
QMS	quality management system
QRS	quality requirements specification
TRS	technical requirements specification

4 Quality requirements

4.1 Quality management system (QMS)

The manufacturer shall operate and maintain a quality management system (QMS) that conforms with ISO 9001, ISO 29001, API Specification Q1 or an equivalent QMS standard.

4.2 Conformity assessment system (CAS)

4.2.1

The CAS provides different levels of assessment of manufacturer control activities. The CAS level is defined by the purchaser using a risk-based approach and included in the purchase order/contract. The defined CAS level may be adjusted by the purchaser during manufacture based on the manufacturer's performance and re-assessment of risk.

NOTE For industrial proven solutions, CAS level D is specified unless risk assessment indicates that a more stringent CAS level is required.

4.2.2

Quality plans and inspection and test plans shall include provision for purchaser intervention activities based on the CAS level selected in the PDS or purchase order. See Table A.1.

4.2.3

The manufacturer's performance in meeting the requirements may be routinely assessed during execution of the scope and, where appropriate, corrective action requested and conformity assessment activities may be increased or decreased consistent with criticality and risk.

4.2.4

If any subcontracted or scope of supply occurs outside of the primary manufacturer location, it shall include interventions within the primary inspection and test plan (ITP) or secondary ITP. It is discouraged to use "hold" (H) within Table A.1, section 3 and recommended to use "surveillance" (S).

5 Certification and traceability

The supplier shall maintain traceability of sub-assembly and major components to the original component manufacturer tag/serial number and, where applicable, associated certification. See ISO 9001:2015, 8.5.2.

6 Evidence — conformance records

Documents and information shall be provided for in accordance with IOGP S-754L.

Annex A (normative)

Purchaser conformity assessment requirements

Table A.1 defines four CAS levels or levels of purchaser assessment.

Table A.1 — Purchaser conformity assessment requirements

	Purchaser assessment activities	CAS			
		A	B	C	D
1	Operational planning and control activities				
1.1	Attend pre-inspection/pre-production meeting	H	S	R	-
2	Design and development activities				
2.1	Final design				
2.1.1	Attend final design review meeting	H	H	H	H
2.2	Manufacturing qualification				
2.2.1	Verification of the iron core assembly for the transformer (IOGP S-754, 1.4.1, 6.7.2)	W	W	S	-
2.2.2	Verification of winding assembly for the transformer (IOGP S-754, 1.4.1, 6.9.2, 6.9.3, Table 17)	H	W	S	-
3	Externally provided products and services (outsourced)				
3.1	Verification and the review of external supplied items such as steel for core and tank, winding conductors and insulation, radiators, tap changers, accessories, insulating liquid, etc. (IOGP S-754, 4.4.3)	W	S	-	-
4	Production and service provision				
4.1	Inspection and test activities as per IOGP S-754				
4.1.1	Performance of type tests, in the absence of a certificate (IOGP S-754, 8.2, Table 17)	H	W	W	R
4.1.2	Visual and dimensional checks (IOGP S-754, 4.3.3, 5.12.1, 5.12.2, 5.13.2, 5.13.3, 6.1.4, 6.2.1 - 6.2.5, 6.2.6, 6.3.1, 6.5.3.1 - 6.5.3.7, 6.6.3, 6.6.5, 6.8, 11.1.2, 12.1.3)	H	W	S	-
4.2	Sub-assembly				
4.2.1	Core and winding pre-tanking inspection (IOGP S-754, 1.4.1)	W	S	-	-
4.3	Functional testing				
4.3.1	Functional testing of all protective and control devices (e.g., SPR, Buchholtz relay, monitoring devices, fan control systems) (IOGP S-754, 6.2.1.1 - 6.2.1.6, 6.2.2.1, 6.2.3.1, 6.2.3.2, 6.2.3.7, 6.2.4.3, 6.3.1.2, 6.3.1.8, 6.6.3.1, 6.6.3.2, 6.6.3.4 - 6.6.3.6, 6.6.3.8.7)	H	H	W	R
4.3.2	Testing of accessories provided as part of the system design (e.g., condition-based monitoring, cooling system, space heaters, OLTC, NGR), if applicable (IOGP S-754, 6.2.1.1 - 6.2.1.6, 6.2.2.1, 6.2.3.1, 6.2.3.2, 6.2.3.7, 6.2.4.3, 6.3.1.2, 6.3.1.8, 6.6.3.1, 6.6.3.2, 6.6.3.4 - 6.6.3.6, 6.6.3.8.7)	H	H	W	R

Table A.1 (continued)

	Purchaser assessment activities	CAS			
		A	B	C	D
4.4	Final tests, including factory acceptance test (FAT)				
4.4.1	Routine testing (IEEE Std C57.12.00, Table 17) (IOGP S-754, 6.6.3.1, 6.6.3.2, 6.6.3.4 - 6.6.3.6)	H	W	W	R
4.4.2	Performance of special tests, if specified (IOGP S-754, 8.2.3, 8.2.5, 8.3.2, 8.5, Table 17)	H	W	W	R
4.4.3	Painting inspection (IOGP S-754, 4.1.9, 6.7.3, 6.17)	W	S	S	-
5	Final Inspection				
5.1	Conformance to purchase order				
5.1.1	Verify the preservation of the transformer before release (IOGP S-754, 6.1.4, 6.6.5.1, 10.1.5 - 10.1.7)	W	W	S	R
5.1.2	Verify the handling and packaging provisions for the transformer before release (IOGP S-754, 10.1)	H	W	S	R
5.1.3	Inspection of loose ship items, spares and special tools, as applicable (IOGP S-754, 10.1.7 - 10.1.11)	W	W	S	-
5.1.4	Release equipment for shipment (IOGP S-754, 10.1.7)	H	H	H	H
Key - No intervention performed H Hold point W Witness point R Review S Surveillance					

Registered Office

City Tower
Level 14
40 Basinghall Street
London EC2V 5DE
United Kingdom
T +44 (0)20 3763 9700
reception@iogp.org

Brussels Office

Avenue de Tervuren 188A
B-1150 Brussels
Belgium
T +32 (0)2 790 7762
reception-europe@iogp.org

Houston Office

15377 Memorial Drive
Suite 250
Houston, TX 77079
USA
T +1 (713) 261 0411
reception-americas@iogp.org

| www.iogp.org

www.Draft

